



Fire EN 16034 - SoundGuard



Brann EN 16034 - Kvillsfors



Brand EN 16034 - Kvillsfors



Document ID: 0004CD(1.00)

Date: 14 December 2019

Page: 1 of 2

Applicable for product codes: D1, EN, ES, G1, G6



# Certificate of constancy of performance

0402-CPR-SC0384-19

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction products

## Openable windows – Product standard, performance characteristics - Fire resisting and/or smoke control characteristics

for use in fire and/or smoke compartmentation and/or escape routes, with specification and performance as specified on page 2 in this certificate.

**Product name: D1, EN, ES, G1, G6, KT991, KT953**

placed on the market under the name or trademark of

**NorDan AB**

Grebbestadsvägen 8  
SE-457 91 Tanumshede, Sweden

and produced in the manufacturing plant

**NorDan AB, Nyboholmsvägen, SE-570 16 Kvillsfors, Sweden**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in annex ZA of the standard

**EN 16034:2014**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

**constancy of performance of the construction product.**

This certificate was first issued on 2019-12-14 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Issued by notified body 0402

The validity of this certificate can be verified on our website.

Signed by: Martin Tillander  
I am the author of this document  
2019-12-14 13:19:07 +01:00

**Martin Tillander**

Product Certification Manager

Certificate 0402-CPR-SC0384-19 | issue 1 | 2019-12-14

**RISE Research Institutes of Sweden AB | Certification**  
Box 857, SE-501 15 Borås, Sweden  
Phone: +46 10-516 50 00  
certifiering@ri.se | www.ri.se



9P06899



Page 1 (2)



## Certificate of constancy of performance

### Specification

Openable windows of timber: EN, KT991 (tilt and turn), ES, KT991 (side-hung).

Door height windows of timber: G6, KT991FD (tilt and turn), G1, KT991FD (side-hung).

Side-hung balcony doors of timber: D1, KT953FD.

For detailed information about the products and conditions for classification, see classification reports no. LBO-632-K/14E, LBO-634-K/14E and LBO-635-K/14E. The products are covered by EN 14351-1.

### Performance

Essential characteristic	Performance
Resistance to fire (for fire compartment uses):	
E:	30*
EI <sub>1</sub> :	30*
EI <sub>2</sub> :	30*
EW:	30*

\* For balcony doors (D1, KT953FD) the class is valid only with fire exposure to the internal side.