

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Openable window with fire resisting and/or smoke control characteristics

for use in fire and/or smoke compartmentation and/or escape routes, with specification and performance as specified on page 2 in this certificate.

Product name: ND NTech Sikkerhetsvindu (ND) (EI30)

placed on the market under the name or trademark of

NorDan AS

Stasjonsveien 46
NO-4460 Moi, Norway

and produced in the manufacturing plant

NorDan AS, Stasjonsveien 46, NO-4460 Moi, Norway

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in annex ZA of the standard

EN 16034:2014

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on 2019-11-19 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Issued by notified body 0402

The validity of this certificate can be verified on our website.

Martin Tillander
Product Certification Manager

Certificate 0402-CPR-SC0357-19 | issue 1 | 2019-11-19

RISE Research Institutes of Sweden AB | Certification
Box 857, SE-501 15 Borås, Sweden
Phone: +46 10-516 50 00
certifiering@ri.se | www.ri.se

2017-07-06



9P06429



Accred. no. 1002
Certification of
Products
ISO/IEC 17065

Specification

Openable window of wood with double glass unit. Max width 1610 mm, max height 2068 mm and max area 3.02 m². For detailed information of the window and the conditions for the classification, see classification report no. 150032-05. The window is covered by EN 14351-1.

Performance

Essential characteristic	Performance
Resistance to fire (for fire compartment uses): E: EI ₁ : EI ₂ : EW:	30 - 30 30