



Certificate of Compliance

Certificate: 2473889

Master Contract: 254383

Project: 2473889

Date Issued: February 17, 2012

Issued to: NorDan AS

Postbox 83/84

Moi, Lund, 11 4465

NO

Attention: Ross Leishman

The products listed below are eligible to bear the CSA Mark shown



M. L. Diallo

Issued by: M. L. Diallo, Ph.D., Eng.

PRODUCTS

CLASS 8029 12 - BUILDING PRODUCTS AND MATERIALS- Windows - (Harmonized Standard)

- **Wooden Dual-Action Window certified to Harmonized Standard AAMA/WDMA/CSA 101/I.S.2/A440-08:**

Model/Type	Primary Product Designator	Positive DP Pa (psf)	Negative DP Pa (psf)	Water Resistance Test Pressure Pa (psf)	Inf/Exf
------------	----------------------------	-------------------------	-------------------------	--	---------

ND Series	Class CW-PG50- Size tested	2400 (50.0)	-2400 (-50.0)	730 (15.0)	A3 Level
Tilt and Turn	1198 mm x 1798 mm (47 x 71 in)-Type DAW				



Certificate: 2473889

Master Contract: 254383

Project: 2473889

Date Issued: February 17, 2012

- Number of sashes: (1) inward-opening sash

DP= Design Pressure

Inf/Exf = Canadian Air Infiltration/Exfiltration

Allowable Glass:

Glass thickness: Exterior: 5.8 mm (0.23") or greater / Interior: 5.8 mm (0.23") or greater

Type of Glass: Exterior: Tempered / Interior: Tempered

Notes:

This Certification does not extend to the substitution of materials or changes in the construction or composition of products, nor factory location without CSA prior written agreement.

APPLICABLE REQUIREMENTS

AAMA/WDMA/CSA101/I.S.2/A440-08 NAFS-North American Fenestration Standard/Specification for windows, doors, and skylights