

Our ref: W22008

10 August 2022

Helen Goldsmith  
Bluesky Certification

- Building Compliance Testing
- Fenestration Product Testing
- Fenestration Product Certification
- CE Marking

[www.buildcheck.co.uk](http://www.buildcheck.co.uk)

Dear Helen

**Re: Audit testing – NorDan (Powodowo)**

Please find below the test results relating to contract W22008, the testing of the Homeguard half glazed single timber door, carried out on 29 July 2022.

A visual check of the window was undertaken before testing against scope GPD+ESD+0302. No differences were identified.

**PAS 24: 2016 – Enhanced security performance requirements for doorsets and windows in the UK**

Test	Test ref number	Result
Mechanical loading test	B.4.5	Pass
Manual check test	B.4.6	Not vulnerable
Manipulation test A	B.4.3	Pass
Manipulation test B	B.4.3	Pass
Security hardware and cylinder test	Annex A	Pass

Please contact us if you have any questions.

Yours sincerely

A handwritten signature in black ink, appearing to read "Sue Peatey".

Sue Peatey  
Laboratory Manager

**Build Check Ltd.**

Unit 3A, Hayloaders, Wotton Road, Brill,  
Nr Aylesbury, Bucks HP18 9UB

t 01494 452713 e [info@buildcheck.co.uk](mailto:info@buildcheck.co.uk)

